



CM/L-5710037013

**JSW CEMENT LTD
SALBONI, WEST MIDNAPORE,
WESTBENGAL**

TEST CERTIFICATE FOR PORTLAND SLAG CEMENT

S.No.	Characteristics	Requirement as Per IS 455:2015	Test Result
	CHEMICAL REQUIREMENTS	% Max.	
1	Magnesium Oxide (% MgO)	10.0	5.01
2	Sulphur Trioxide (% SO ₃)	3.5	1.70
3	Sulphide Sulphur (% S)	1.5	0.17
4	Loss On Ignition (%)	5.0	1.56
5	Insoluble Residue (%)	4.0	1.12
6	Chlorides (%)	0.1	0.006
	PHYSICAL REQUIREMENTS		
1	Fineness (M ² /Kg)(Min)	225	370
2 a	Normal Consistency (%)		31.50
b	Setting Time (minutes)		
a)	Initial(Min)	30	170
b)	Final(Max)	600	255
3	Soundness		
a)	Le-chatelier (mm)(Max)	10	0.500
b)	Auto Clave (%) (Max)	0.8	0.028
4	Compressive Strength (MPa)		
a)	72 ± 1h (3 days)(Min)	16	20.70
b)	168 ± 2h(7 days)(Min)	22	30.74
c)	672 ± 4h (28 days)(Min)	33	45.32

Remarks: Temperature during testing is 27+/-2degree centigrade.
Specific Gravity: -2.96

**WEEK NO: 36
03.09.2023 – 09.09.2023**

JSW CEMENT Ltd.

Authorized Signatory