



CM/L-5710037013

**JSW CEMENT LTD.,
SALBONI, WEST MIDNAPORE, WESTBENGAL**



TEST CERTIFICATE FOR PORTLAND SLAG CEMENT

S.No.	Characteristics	Requirement as Per IS 455:2015	Test Result
	CHEMICAL REQUIREMENTS	% Max.	
1	Magnesium Oxide (% MgO)	10.0	3.70
2	Sulphur Trioxide (% SO ₃)	3.5	1.84
3	Sulphide Sulphur (% S)	1.5	0.15
4	Loss On Ignition (%)	5.0	1.53
5	Insoluble Residue (%)	4.0	0.82
6	Chlorides (%)	0.1	0.007
	PHYSICAL REQUIREMENTS		
1	Fineness (M ² /Kg)(Min)	225	379
2 a	Normal Consistency (%)		31.00
b	Setting Time (minutes)	30	150
a)	Initial(Min)	600	255
b)	Final(Max)		
3	Soundness		
a)	Le-chatelier (mm)(Max)	10	1.000
b)	Auto Clave (%) (Max)	0.8	0.027
4	Compressive Strength (MPa)		
a)	72 ± 1h (3 days)(Min)	16	29.00
b)	168 ± 2h(7 days)(Min)	22	38.10
c)	672 ± 4h (28 days)(Min)	33	54.25

Remarks: Temperature during testing is 27+/-2degree centigrade.
Specific Gravity: -2.98

**WEEK NO: 28
09.07.2023 – 15.07.2023**

JSW CEMENT Ltd.

Authorized Signatory