



JSW PSC Cement

THE LEADERS' CHOICE

TEST CERTIFICATE

Portland Slag Cement as per IS 455:2015

REF.: JSW/QA/2023/A-01

DATE : 12-11-2023

WEEK NO. : 41

08-10-2023 14-10-2023

CHARACTERISTIC	RESULTS OBTAINED	REQUIREMENT OF IS 455:2015
(A) CHEMICAL COMPOSITION		
(i) Magnesia (MgO), % by mass	5.21	10.0 Maximum
(ii) Insoluble Residue, % by mass	0.41	4.0 Maximum
(iii) Sulphuric Anhydride (SO ₃) % by mass	2.07	3.5 Maximum
(iv) Sulphide Sulphur (S)	0.24	1.5 Maximum
(v) Loss on Ignition % by mass	0.86	5.0 Maximum
(vi) Total Chloride (Cl), % by mass	0.014	0.10 Maximum
(B) PHYSICAL TESTING		
1. Fineness of Cement		
Sp.Surface (m ² /kg)	362	225 m ² /kg minimum
2. Soundness		
Le-Chatelier Expansion (mm)	1.00	10 mm Maximum
Autoclave Expansion (%)	0.054	0.8 % Maximum
3. Setting Time		
Initial (in Minutes)	210	Not less than 30 minutes
Final (in Minutes)	265	Not more than 600 minutes
4. Compressive Strength (MPa)		
(a) At 72 ± 1 Hr.	26.21	16 MPa Minimum
(b) At 168 ± 2 Hrs.	33.01	22 MPa Minimum
(c) At 672 ± 4 Hrs.	44.91	33 MPa Minimum
5. Normal Consistency	31.50	--
6. GGBS addition (%)	55.00	25% MIN & 70% MAX

Remarks :

- Temperature during testing - 27 ± 2° c.
- Portland Slag Cement conforms to the requirement of IS 455:2015 in all respects.
- Specific Gravity :- 3.05

Address:


JSW CEMENT LIMITED
 Village- Khar Karavi, Post - Gadab
 Taluka- Pen, District- Raigad, PIN- 402107
 Maharashtra. +91 2143 277601/2



Prepared By
Officer-QC



Checked By
SH -QC



Approved By
HOD-QC