



ISO 9001, ISO 14001, ISO 50001 & OHSAS 18001  
Certified by IRQS



**JSW CEMENT LTD.,  
VIJAYANAGAR WORKS**

**IS: 455: 2015**

**TEST CERTIFICATE FOR PORTLAND SLAG CEMENT  
(POWER PRO)**

S.No.	Characteristics	Requirement as Per IS 455:2015	Test Result
	<b>CHEMICAL REQUIREMENTS</b>	% Max.	
1	Magnesium Oxide (% MgO)	10.0	5.50
2	Sulphur Trioxide (% SO <sub>3</sub> )	3.5	1.77
3	Sulphide Sulphur (% S)	1.5	0.21
4	Loss On Ignition (%)	5.0	0.88
5	Insoluble Residue (%)	4.0	0.90
6	Chlorides (%)	0.1	0.013
7	Alkali Content (%) as Na <sub>2</sub> O	0.6	0.39
	<b>PHYSICAL REQUIREMENTS</b>		
1	Normal Consistency	NA	29.75
2	Fineness (M <sup>2</sup> /Kg)(Min)	225	342
3	Setting Time (minutes)		
	a) Initial(Min)	30	140
	b) Final(Max)	600	235
4	Soundness		
	a) Le-chatelier (mm)(Max)	10	1.00
	b) Auto Clave (%) (Max)	0.8	0.006
5	Compressive Strength (MPa)		
	a) 72 ± 1h (3 days)(Min)	16	21.27
	b) 168 ± 2h(7 days)(Min)	22	32.97
	c) 672 ± 4h (28 days)(Min)	33	54.19

**Week No. 41**

**08.10.2023-14.10.2023**

  
*Authorized signatory*